



18 August 2017

Mean Well Enterprises Co., Ltd.  
No. 28, Wuquan 3rd Rd., Wugu Dist.,  
New Taipei City 248,  
Taiwan

C/- Dekra Testing and Certification (Shanghai) Ltd. Guangzhou Branch

Dear Sir

**Certificate of Approval – SAA-171915-EA  
Independent SELV LED Controlgears  
Model No.: ELG-150-XY Series**

We are pleased to advise that your application for certification of the above electrical product has been successful.

Please ensure that you keep the enclosed Certificate in a safe place as it is your product approval record.

The approved product must now be marked with the SAA Number SAA-171915-EA or may be marked with the Regulatory Compliance Mark (RCM). The RCM must be used in accordance with the conditions set out in the relevant parts of AS/NZS 4417.

Please note that if the electrical product is modified in any way or your company details change you are required to notify this office of the details of the modification. You can either download the required form from our web page or contact our office.

As part of our operational guidelines we are required to check that a certified product remains compliant during the term of the Certificate. At some stage during this term we may request a sample for evaluation.

If you need any further information or need to discuss this letter please don't hesitate to contact our office.

Yours sincerely

A handwritten signature in black ink, appearing to be 'J. K.', written over a light blue horizontal line.

**For and on behalf of  
SAA Approvals Pty Ltd**

ABN 91 125 451 327

P. +61 7 3393 9455

F. +61 7 3393 9499

E. [info@saaapprovals.com.au](mailto:info@saaapprovals.com.au)

W. [www.saaapprovals.com.au](http://www.saaapprovals.com.au)

PO Box 189, Cannon Hill QLD 4170  
5/20 Rivergate Place, Murarrie QLD 4172



A P P R O V A L S ®

## Certificate of Approval

**Certificate No.:** SAA-171915-EA

**Certificate Holder:** Mean Well Enterprises Co., Ltd.  
No. 28, Wuquan 3rd Rd., Wugu Dist.,  
New Taipei City 248,  
Taiwan

**Class Description:** Power Supply or Charger  
**Product Description:** Independent SELV LED Controlgears  
**Brand Name:** MEAN WELL  
**Model No.:** ELG-150-XY Series  
**Markings:** Input: 100-240Vac 50/60Hz 1.7A  
Output: 12-54Vdc 84-151.2W  
ta:55°C tc:90°C, IP67 or IP65

**Standard:** AS/NZS IEC 61347.2.13:2013  
AS/NZS 61347.1:2016

**Conditions:** Nil

**Approval Mark:** SAA-171915-EA or RCM

**Date First Registered:** 18 August 2017

**Date of Expiry:** 18 August 2022


For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 18-08-17 171915/1



A P P R O V A L S ®

## Certificate of Approval

\* Addendum \*

**Certificate No.:** SAA-171915-EA

**Date of Issue:** 18 August 2017

**Class Description:** Power Supply or Charger

**Product Description:** Independent SELV LED Controlgears

**General Modification:**

'X' denotes output voltage and can be '12' to '54' for 12-54Vdc; and

'Y' denotes dimming function and can be:-

blank for Cable for I/O connection, rated IP67;

'A' for adjusted through internal potentiometer, rated IP65;

'B' for adjustable through output cable with 0-10Vdc or 10V PWM signal or resistance, rated IP67;

'AB' for adjusted through internal potentiometer or output cable with 0-10Vdc or 10V PWM signal or resistance, rated IP65;

'D' for smart timer dimming, rated IP67;

'DA' for DALI function, rated IP67;

'ADA' for DALI function and adjusted through internal potentiometer, rated IP65;

'D2' for smart timer dimming programmed by output cable, rated IP67; or

'AD2' for smart timer dimming programmed by output cable and adjusted through internal potentiometer, rated IP65.


For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 18-08-17 171915/2