



Test Report : GE30I18

30WAC-DC Interchangeable Industrial Adaptor

■ DESIGN VERIFY TEST

Output Function Test

Input Function Test

Protection Function Test

■ SAFETY TEST

Safety Test

■ RELIABILITY TEST

Other test

DESIGN VERIFY TEST
OUTPUT FUNCTION TEST

NO	TEST ITEM	SPECICATION	TEST CONDITION	RESULT	VERDICT
1	RIPPLE & NOISE	180mVp-p (Max)	I/P:230VAC O/P:FULL LOAD Ta:25°C	32 mVp-p	P
2	VOLTAGE TOLERANCE	-3% ~ +3% (Max)	I/P:90VAC~264VAC O/P:FULL~MIN. LOAD Ta:25°C	-0.41% ~ +0.49%	P
3	LINE REGULATION	-1% ~ +1% (Max)	I/P:90VAC ~264VAC O/P:FULL LOAD Ta:25°C	-0.02% ~ +0.01%	P
4	LOAD REGULATION	-3% ~ +3% (Max)	I/P:230VAC O/P:FULL ~MIN LOAD Ta:25°C	-0.44% ~ +0.47%	P
5	SET UP TIME	4000 mS	I/P:230VAC O/P:FULL LOAD Ta:25°C	3054 mS	P
6	RISE TIME	100 mS	I/P:230VAC O/P:FULL LOAD Ta:25°C	52.0 mS	P
7	HOLD UP TIME	10 mS (Min)	I/P:115VAC O/P:FULL LOAD Ta:25°C	27.8 mS	P

INPUT FUNCTION TEST

NO	TEST ITEM	SPECICATION	TEST CONDITION	RESULT	VERDICT
1	VOLTAGE RANGE	90VAC ~ 264VAC	I/P:TESTING O/P:FULL LOAD Ta:25°C	63V ~ 264V	P
2	FREQUENCY RANGE	50HZ - 60HZ (Typ) NO DAMAGE OSC	I/P: 100VAC ~ 240VAC O/P:FULL~MIN LOAD Ta:25°C	TEST: OK	P
3	EFFICIENCY	87%	I/P:230VAC O/P:FULL LOAD Ta:25°C	87.31%	P
4	AVERAGE EFFICIENCY	86.95 % (DoE Level VI)	I/P:115VAC O/P:25% 、 50% 、 75% 、 100% LOAD Ta:25°C	87.93%	P
5	AC CURRENT	0.7A (Max)	I/P: 100VAC O/P:FULL LOAD Ta:25°C	0.56A	P
6	NO LOAD POWER CONSUMPTION	< 0.075W (Max)	I/P:230VAC O/P: NO LOAD Ta:25°C	0.0722W	P

7	INRUSH CURRENT	< 80A COLD START	I/P:230VAC O/P:FULL LOAD Ta:25°C	52.0A	P
8	LEAKAGE CURRENT	< 0.25mA	I/P:240VAC O/P:Min LOAD Ta:25°C	L-FG: 0.02mA N-FG: 0.02mA	P

PROTECTION FUNCTION TEST

NO	TEST ITEM	SPECICATION	TEST CONDITION	RESULT	VERDICT
1	OVER LOAD PROTECTION	110% ~ 200%	I/P:230VAC O/P:TESTING Ta:25°C	136% HICCUP MODE RESET : AUTO RECOVER	P
2	OVER VOLTAGE PROTECTION	115% ~ 135%	I/P:230VAC O/P:MIN LOAD Ta:25°C	Clamp by ZENER diode	P
3	SHORT PROTECTION	SHORT OUTPUT 1 HOUR NO DAMAGE	I/P:264VAC O/P:FULL LOAD Ta:25°C	NO DAMAGE HICCUP MODE RESET AUTO RECOVER	P

■ SAFETY TEST

SAFETY TEST

NO	TEST ITEM	SPECICATION	TEST CONDITION	RESULT	VERDICT
1	WITHSTAND VOLTAGE	I/P-O/P:4242 VDC/min	I/P-O/P:4242 VDC/min Ta:25°C	I/P-O/P: 0.03uA NO DAMAGE	P
2	ISOLATION RESISTANCE	I/P-O/P:500VDC>100MΩ	I/P-O/P:500 VDC Ta:25°C	I/P-O/P>100MΩ NO DAMAGE	P

■ RELIABILITY TEST

OTHER

NO	TEST ITEM	SPECICATION	TEST CONDITION	RESULT	VERDICT
1	MTBF	MIL-KDBK-217F NOTICES 2 PARTS COUNT TOTAL FAILURE RATE : 1.6605 M.T.B.F : 602234HRS			P

TEST RESULT	TESTER	APPROVAL
PASS	PETER CHENG	VINCENT TSENG